



Certificate of Conformity



Global-Mark Pty Ltd,
Suite 4.07, 32 Delhi Road,
North Ryde NSW 2113,
Australia

Tel: +61 (0)2 9886 0222 -
www.Global-Mark.com.au

Certificate Holder:
Fletcher Insulation Pty Ltd
127 Frankston -
Dandenong Rd,
Dandenong South, VIC,
3175
Tel: 1300 654 444
E: info@insulation.com.au
www.insulation.com.au

Certificate number: CM30006 Rev 5

THIS IS TO CERTIFY THAT

Pink® Wall and Ceiling Batts; Pink Permastop® Building Blanket, Permastop® Tropic Building Blanket, Permatuff™ Building Blanket, Pink® Sonomatt Blankets; Pink® Partition, FirmaSoft™ Wall and Ceiling Batts, Pink® NoiseSTOP, Pink® Thermal Slab and FI22 Ductwrap, FI24 General Purpose, FI32 Semi Rigid, FI48 Rigid HVAC boards and blankets

| | |
|--|---|
| Type and/or use of product: Thermal insulation for use in roofs, ceilings, walls and floors of residential and commercial buildings. | Description of product: Glass wool type bulk insulation supplied as batts and blankets with thickness between 50 mm and 285 mm and nominal density between 8 kg/m ³ and 48 kg/m ³ . |
|--|---|

COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S)

BCA 2022

| | Volume One | Volume Two and ABCB Housing Provisions | | |
|--|-------------|---|----------------------------|------------------------------------|
| Performance Requirement(s) | | | | |
| Deemed-to-Satisfy Provision(s): | J3D7 | Roofs and ceilings of a sole-occupancy unit of a Class 2 building or a Class 4 part of a building | 13.2.2(1) & (3) | Building fabric thermal insulation |
| | J3D8 | External walls of a sole-occupancy unit of a Class 2 building or a Class 4 part of a building | 13.2.3 | Roofs and ceilings |

Scope of certification: The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website www.abcb.gov.au. This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the certificate holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.

Disclaimer: The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate.

The purpose of Global-Mark **construction site audits** is to confirm the practicability of installing the product; and to confirm the appropriateness and accuracy of installation instructions. In placing the **CodeMark mark** on the product/system, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the **expertise of external bodies** (laboratories, and technical experts).

Herve Michoux
Global-Mark Managing Director

Peter Gardner
Unrestricted Building Certifier

Date of issue: 13/12/2023

Date of expiry: 29/06/2026



| | | | | | |
|--|---|--|---|---|---|
| | | J3D10 | Floors of a sole-occupancy unit of a Class 2 building or a Class 4 part of a building | 13.2.5 | External walls |
| | | J4D3(1) & (3) | Thermal construction – general | 13.2.6 | Floors and subfloor walls |
| | | J4D4 | Roof and ceiling construction | 13.2.7 | Attached Class 10a buildings |
| | | J4D6 | Walls and glazing | | |
| | | J4D7 | Floors | | |
| | State or territory variation(s): | NSW Section J (NCC 2019 A1 NSW Section J) | Energy Efficiency – Class 2 or Class 4 part of a building (up to V3 BASIX dwellings) | NSW H6 (NCC 2022 NSW Part H6) | Energy Efficiency |
| | | NSW Section J (NCC 2022 Section J) | Energy Efficiency – Class 2 or Class 4 part of a building (V4 or later BASIX dwellings) | NSW H6 (NCC 2019 A1 NSW 2 Energy Efficiency) | Energy Efficiency (if up to V3 BASIX dwellings required) |
| | | NSW Section J (NCC 2019 A1 NSW Section J) | Energy Efficiency – Class 2 or Class 4 part of a building (BASIX Alterations and Additions) | NSW H6 (NCC 2022 NSW Part H6) | Energy Efficiency (if V4 or later BASIX dwellings required) |
| | | NSW Section J (NCC 2022 Section J) | Energy Efficiency – Class 3 or 5-9 buildings | NSW H6 (NCC 2019 A1 NSW 2 Energy Efficiency) | Energy Efficiency (If BASIX Alterations and Additions required) |
| | | NSW Part J1 | Energy use - Class 3, 5, 6,7,8,9 | NT Part H6 | Energy Efficiency |
| | | NSW J3D7 | No requirement, does not apply | Tas Part H6 (NCC 2019 A1 Part 2.6) | Energy Efficiency – Building (NCC 2019 A1 P2.6.1) |
| | | NSW J3D8 | No requirement, does not apply | NSW 13.2.3 | Roofs and ceilings |
| | | NSW J3D10(1)(2) & (4) | No requirement, does not apply | NSW 13.2.5 | External walls |
| | | NSW J4D3(1) & (3) | Thermal construction—general | NSW 13.2.6 | Floors and subfloor walls |
| | | NSW J4D6 | Walls and glazing | NSW 13.2.7 | No requirement, does not apply |
| | | Tas part J3 (NCC 2019 A1 Section J) | Energy Efficiency – Class 2 and Class 4 part of a building | NT 13.2.2(1) & (3) | Building fabric thermal insulation |
| | | | | NT 13.2.3 | Roofs |

Certificate of Conformity

| | | | | |
|--|--|--|------------------|-----------------------------------|
| | | | NT 13.2.5 | External walls |
| | | | NT 13.2.6 | Attached Class 10a buildings |
| SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B | | | | |
| Limitations and conditions: | | | | Building classification/s: |
| <p>1. Product selection, and incorporation into the building design, shall be made by a person who:</p> <ul style="list-style-type: none"> a. Has received training in the use, application and technical aspects of the product; and b. Has ready access to all to the relevant technical information related to the product use. | | | | Unrestricted |
| <p>2. Product installation shall be carried out in accordance with the requirements in Appendix A, Section A5 by a competent person under the direction of a Builder, both of whom:</p> <ul style="list-style-type: none"> a. Have received training in the product installation and been issued a ICANZ Insulation Installer Certificate; and b. Issue an Installation Guarantee Certificate. | | | | Unrestricted |
| <p>3. NSW Section J variations:</p> <ul style="list-style-type: none"> a. For a Class 2 building or a Class 4 part of a building, where a relevant development consent or an application for a complying development certificate requires compliance with a BASIX Single Dwelling or Multi Dwelling Certificate issued under Version 3.0 or earlier, NSW Section J of NCC 2019 Volume One Amendment 1 applies. b. For a Class 2 building or a Class 4 part of a building, where a relevant development consent or an application for a complying development certificate requires compliance with a BASIX Single Dwelling or Multi Dwelling Certificate issued under Version 4.0 or later, Section J of NCC 2022 Volume One applies. c. For a Class 2 building or a Class 4 part of a building, where a relevant development consent or an application for a complying development certificate requires compliance with a BASIX Alterations and Additions Certificate, NSW Section J of NCC 2019 Volume One Amendment 1 applies. d. For a Class 3 building or Class 5 to 9 building: <ul style="list-style-type: none"> i. From 1 May 2023 to 30 September 2023 NSW Section J of NCC 2019 Volume One Amendment 1 may apply instead of Section J of NCC 2022 Volume One. ii. From 1 October 2023 Section J of NCC 2022 Volume One applies. | | | | Class 2 to 9 buildings |
| 4. Volume 1 NT Section J variation has no applicable requirement. | | | | Class 2 to 9 buildings |
| 5. In Tasmania: compliance with Volume Two Part H6 is a performance solution. | | | | Class 1 and 10 |
| 6. The R-Value of insulation, including insulation used to mitigate thermal bridging, is reduced if it is compressed. The allocated space for insulation must therefore allow the insulation to be installed so that it maintains its correct thickness to achieve the product's stated R-Value. | | | | Unrestricted |
| 7. Permastop® Building Blankets cannot be used as sarking. | | | | Unrestricted |

APPENDIX A – PRODUCT TECHNICAL DATA

A1 Type and intended use of product

Refer to page 1 of this Certificate.

A2 Description of product

Fletcher Insulation is a glass wool fibre type bulk insulation complying with AS/NZS 4859.1:2018 Thermal insulation materials for buildings – Part 1: General criteria and technical provisions.

- Pink® Wall, Floor and Ceiling Batts, including Pink® Partition and Pink® SoundBreak™, for incorporation into the cavity spaces between framing members.
- Permastop® Building Blanket, lined with a reflective foil laminate.
- Permastop® Tropic Building Blanket, lined with a reflective foil laminate.
- Permatuff™ Building Blanket, lined with a reflective polyweave foil laminate.
- Pink® Sonomatt Blanket, lined with a black matt facing for partitions and screens.
- FirmaSoft™ Wall and Ceiling Batts for incorporation into the cavity between wall framing members and the spaces between ceiling support members.
- Pink® NoiseSTOP, rigid board with black Durasorb poly-woven fabric facing for concrete ceilings, floors and walls.
- Pink® Thermal Slab, rigid board with reflective foil facing for under slab soffits
- General purpose, glass wool insulation blanket for HVAC ductwork and roofing .
- FI22 Ductwrap, glasswool insulation blankets faced with reflective foil and a 150mm lap for sealing external lagging of HVAC ductwork.

A3 Product specification

Table 1 contains the specifications for products within the scope of this certificate. Refer to the referenced documents in Appendix A, Section A2 and the specified Technical Data Sheets for product type and size.

Table 1: Fletcher Insulation Product Specifications

| Model Name | R-value (m ² K/W) | Thickness (mm) | Density (kg/m ³) |
|------------------------|------------------------------|----------------|------------------------------|
| FI22 General Purpose | R2.0 | 75 | 22 |
| FI24 General Purpose | R0.7 | 25 | 24 |
| FI32 Semi Rigid Sheets | R1.5 | 50 | 32 |
| FI32 Semi Rigid Sheets | R3.0 | 100 | 32 |
| FI48 Rigid Board | R1.5 | 50 | 48 |
| FI48 Rigid Board | R3.0 | 100 | 48 |
| FirmaSoft® Wall | R1.5 | 70 | 11 |
| FirmaSoft® Wall | R2.0 | 90 | 11 |

Certificate of Conformity

| Model Name | R-value (m ² K/W) | Thickness (mm) | Density (kg/m ³) |
|---------------------|------------------------------|----------------|------------------------------|
| FirmaSoft® Wall HD | R2.5 | 90 | 20 |
| FirmaSoft® | R3.0 | 155 | 8 |
| FirmaSoft® Ceilling | R3.5 | 175 | 8.88 |
| FirmaSoft® Ceilling | R4.1 | 215 | 8.9 |
| FirmaSoft® Ceilling | R5.0 | 220 | 12.2 |
| Pink® Batts Wall | R1.5 | 70 | 11 |
| Pink® Batts Wall | R2.0 | 90 | 11 |
| Pink® Batts Wall HD | R2.0 | 70 | 23 |
| Pink® Batts Wall HD | R2.5 | 90 | 20 |
| Pink® Batts Ceiling | R2.5 | 130 | 8 |
| Pink® Batts Ceiling | R3.0 | 155 | 8 |
| Pink® Batts Ceiling | R4.1 | 195 | 9 |
| Pink® Batts Ceiling | R6.0 | 250 | 12 |
| Pink® Batts Ceiling | R7.0 | 285 | 12 |
| Pink® SoundBreak | R1.7 | 60 | 24 |
| Pink® SoundBreak | R3.1 | 110 | 24 |
| Pink® Partition 11 | R1.2 | 50 | 11 |
| Pink® Partition 11 | R1.8 | 75 | 11 |
| Pink® Partition 11 | R2.1 | 90 | 11 |
| Pink® Partition 11 | R2.5 | 110 | 11 |
| Pink® Partition 11 | R3.5 | 165 | 11 |
| Pink® Partition 14 | R1.3 | 50 | 14 |
| Pink® Partition 14 | R1.9 | 75 | 14 |
| Pink® Partition 14 | R2.2 | 90 | 14 |
| Pink® Partition 24 | R0.7 | 25 | 24 |
| Pink® Partition 24 | R1.4 | 50 | 24 |
| Pink® Partition 24 | R2.1 | 75 | 24 |
| Pink® Partition 24 | R2.5 | 90 | 24 |

Certificate of Conformity

| Model Name | R-value (m ² K/W) | Thickness (mm) | Density (kg/m ³) |
|------------------------|------------------------------|----------------|------------------------------|
| Pink® Partition 24 | R2.8 | 100 | 24 |
| Pink® Partition 32 | R1.5 | 50 | 32 |
| Pink® Partition 32 | R2.7 | 90 | 32 |
| Pink® Partition 32 | R3.0 | 100 | 32 |
| Pink® Building Blanket | R1.3 | 55 | 11.8 |
| Pink® Building Blanket | R3.0 | 130 | 10.45 |
| Pink® Building Blanket | R3.6 | 130 | 18 |
| Pink® NoiseSTOP | R1.5 | 50 | 32 |
| Pink® NoiseSTOP | R3.0 | 100 | 32 |
| Pink® Thermal Slab | R1.5 | 50 | 32 |
| Pink® Thermal Slab | R3.0 | 100 | 32 |

Design of building elements incorporating Fletcher Insulation products shall be carried out in accordance with AS/NZS 4859.2:2018 Thermal insulation materials for buildings – Part 2: Design.

Specification of Fletcher Insulation products shall be carried out in accordance with the relevant Fletcher Insulation Technical Data Sheet:

- Fletcher Insulation Technical Data Sheet – Pink® Batts: Wall, Thermal insulation for residential wall applications, Ref.: RTDS7_Revision_0_Issue Date 10102019.
- Fletcher Insulation Technical Data Sheet – Pink® Batts: Floor, Thermal insulation for residential flooring applications, Ref.: RTDS8_Revision_1_Issue Date 01032023.
- Fletcher Insulation Technical Data Sheet – Pink® Batts: Ceiling, Thermal insulation for residential ceiling applications, Ref.: RTDS9_Revision_2_Issue Date 06082021.
- Fletcher Insulation Technical Data Sheet – Pink® Partition, Non combustible thermal and acoustic insulation for partitions and wall systems, Ref.: CTDS1_Revision_4_Issue Date 18112021.
- Fletcher Insulation Technical Data Sheet – Pink® Soundbreak™, High performance acoustic insulation, Ref.: RTDS3_Revision_5_Issue Date 30082022.
- Fletcher Insulation Technical Data Sheet – Pink® Building Blanket, Non-combustible thermal and acoustic insulation blanket for roofs, Ref.: HTDS4_revision_2_Issue Date 22092020.
- Fletcher Insulation Technical Data Sheet – FirmaSoft™ Ceiling Batts: Ceiling, Thermal insulation for residential ceiling applications, Ref.: RTDS11_Revision_1_Issue Date 20012021.
- Fletcher Insulation Technical Data Sheet – General Purpose, Insulation blanket for mechanical services, Ref.: HITDS6_Revision_3_Issuedate 11102022
- Fletcher Insulation Technical Data Sheet – FI32 Semi-Rigid Insulation, HVAC internal duct liner, Ref.: HITDS3_Revision_4_Issuedate 23022021.
- Fletcher Insulation Technical Data Sheet – FI48 Rigid Glasswool Sheets and Acoustic Blanket, Medium weight equipment insulation, Ref.: HITDS_Revision_3_Issuedate 24042020.
- Fletcher Insulation Technical Data Sheet – Pink® NoiseSTOP™ Acoustic decorative panels, Ref : CTDS5_Revision_3_Issue Date 26072021
- Fletcher Insulation Technical Data Sheet – Pink® Thermal Slab Commercial Under Slab/Soffit Insulation, Ref : CTDS3_Revision_3_Issue Date 04032021
- Fletcher Insulation Technical Data Sheet – FI22 Ductwrap, Low Density Lightweight Ductwork Insulation Blanket, Ref.: HITDS5_Revision_1_Issuedate 13102022

Also refer to the relevant Fletcher Insulation Safety Use Information Sheet:

- Fletcher Insulation Safety Use Information Sheet – FBS-1 Glasswool Bio-Soluble Insulation®, Ref.: SUI01_Revision_1_Issue Date 310122.

- Fletcher Insulation Safety Use Information Sheet – FirmaSoft® Batts, Ref.: SUI520_Revision_1_Issue Date 310122.

A4 Manufacturer and manufacturing plant(s)

Fletcher Insulation Pty Ltd – 127 Frankston - Dandenong Rd, Dandenong South, VIC, 3175

A5 Installation requirements

Installation shall be carried out in accordance with AS 3999:2015 Bulk thermal insulation – Installation, and the relevant Fletcher Insulation installation Guide below:

- Fletcher Insulation Installation Guide – Pink® Building Blanket, Permastop® Building Blanket, Permastop® Tropic Building Blanket, Permatuff™ Building Blanket, Pink® Sonomatt Blanket® Batts , Ref.: IG01_Revision_2_Issue Date 08062022
- Fletcher Insulation Installation Guide – FirmaSoft™ Glasswool Batts, Ref.: IG15_Revision_0_Issue Date 02062020
- Fletcher Insulation Installation Guide – Pink® Wall and Ceiling Batts, Ref.: IG9_Revision_2_Issue Date 28042022
- Fletcher Insulation Installation Guide – Pink® Thermal Slab and Pink® NoiseSTOP, Ref.: IG10_Revision_3_Issue Date 23052022
- Fletcher Insulation Installation Guide – Pink® Partition, Ref.: IG12_Revision_0_Issue Date 31102022
- AS 3999:2015 Bulk thermal insulation — Installation

A6 Other relevant technical data

Any referenced documents within the technical literature identified in Appendix A, A3 and Appendix A, A5.

APPENDIX B – EVALUATION STATEMENTS

B1 Evaluation methods

The following assessment methods have been used to determine compliance with NCC 2022:

| Code Clause | Assessment Method(s) | Evidence of suitability | Evidence reference in B2 |
|--|-----------------------|--|--------------------------|
| Volume One | | | |
| J3D7 | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| J3D8 | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| J3D10 | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| J4D3(1) & (3) | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| J4D4 | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| J4D6 | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| J4D7 | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NSW Section J (NCC 2019 A1 NSW Section J) | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NSW Section J (NCC 2022 Section J) | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NSW J4D3(1) & (3) | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |

| Code Clause | Assessment Method(s) | Evidence of suitability | Evidence reference in B2 |
|--|-----------------------|--|--------------------------|
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NSW J4D6 | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| Tas part J3 (NCC 2019 A1 Section J) | Volume One A2G3(2)(a) | Volume One A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume One A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| The assessment methods and evidence of suitability for state and territory variations are as per the main clauses. | | | |
| Volume Two and ABCB Housing Provisions | | | |
| 13.2.2(1) & (3) | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| 13.2.3 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| 13.2.5 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| 13.2.6 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| 13.2.7 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NSW H6 (NCC 2022 NSW Part H6) | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NSW H6 (NCC 2019 A1 NSW 2 Energy Efficiency) | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NT Part H6 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| Tas Part H6 (NCC 2019 A1 Part 2.6) | Volume Two A2G2(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |

| Code Clause | Assessment Method(s) | Evidence of suitability | Evidence reference in B2 |
|--------------------|-----------------------|--|--------------------------|
| NSW 13.2.3 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NSW 13.2.5 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NSW 13.2.6 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NSW 13.2.7 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NT 13.2.2(1) & (3) | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NT 13.2.3 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NT 13.2.5 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |
| NT 13.2.6 | Volume Two A2G3(2)(a) | Volume Two A5G3(1)(d) – Report issued by an Accredited Testing Laboratory | Items 2 to 7 |
| | | Volume Two A5G3(1)(e) – Certificate or report from a professional engineer or other appropriately qualified person | Item 1 |

B2 Reports

The following reports have been used as evidence to determine compliance with NCC 2022:

| Ref | Author | Reference | Date | Description | NATA Registration |
|-----|----------------------|---------------------|------------------------|---|---|
| 1 | James M. Fricker | N/A | 17/01/2023 | Thermal Resistance Tests To AS/NZS 4859 Parts 1 & 2:2018 - Certification | N/A |
| 2 | AWTA Product Testing | Test No.: 19-005178 | Issue date: 01/10/2019 | Testing steady-state thermal transmission properties by means of the heat flow apparatus, in accordance with ASTM C518-2017, for "Pink Batts R4.0". | Performance & Approvals Testing: Accreditation No. 1356 |
| 3 | AWTA Product Testing | Test No.: 19-005179 | Issue date: 29/10/2019 | Testing steady-state thermal transmission properties by means of the heat flow apparatus, in accordance with ASTM C518-2017, for "Pink Batts R2.2". | Performance & Approvals Testing: Accreditation No. 1356 |

Certificate of Conformity

| | | | | | |
|---|----------------------|---------------------|------------------------|--|--|
| 4 | AWTA Product Testing | Test No.: 19-005180 | Issue date: 08/11/2019 | Testing steady-state thermal transmission properties by means of the heat flow apparatus, in accordance with ASTM C518-2017, for "Pink Batts R3.6 HD". | Performance & Approvals Testing: Accreditation No. 1356 |
| 5 | AMTL | DND-04-0122 | _13/01/2022_ | AS/NZS 4859.1 Compliance Report | NATA Accreditation Number: 16869 Accredited for compliance with ISO/IEC 17025 - Testing |
| 6 | AMTL | DND-04-0125 | _18/01/2022_ | AS/NZS 4859.1 Compliance Report | NATA Accreditation Number: 16869 Accredited for compliance with ISO/IEC 17025 - Testing |
| 7 | AMTL | DND-04-0161 | _13/10/2023_ | AS/NZS 4859.1 Compliance Report | NATA Accreditation Number: 16869 Accredited for compliance with ISO/IEC 17025 - Testing |

The Certificate Holder has chosen not to make the above identified evidence of compliance publicly available, due to the documents being considered commercial in confidence.